

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 6200-1632:100

Page 1 of 1

CATEGORY: Exit Signs

LISTEE: Active Safety Corporation, 5E 4800 South, Murray, Utah 84107
Contact: Manny Muniz (916) 989-3193 FAX (916) 989-1493

DESIGN: Models 2001 and 2002 framed and frameless photoluminescent exit signs. Units illuminate a legally required integral "EXIT" legend, using Strontium Oxide Aluminate pigment to form the legend and directional indicators. The framed signs have a 0.6mm thick metal substrate material and photoluminescent placard inside the frame that is provided with "EXIT" legend knockouts with each letter and optional directional indicator knockouts. The frameless placards have a 1mm thick PVC substrate material and photoluminescent background and opaque letters spelling the word "EXIT" with optional directional indicators. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 90 minutes
Legible viewing distances are: 50 feet = Model 2001 frameless
75 feet = Model 2002 framed

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. For indoor use only.

MARKING: Listee's name, model number, legible viewing distance, and UL label.

APPROVAL: Listed as photoluminescent exit signs for use where permitted by code and only in locations where a minimum 5 foot-candle external unfiltered fluorescent illumination source is present on the sign face, is deemed reliable and is supplied by a circuit not controlled by automatic timers or sensors, and whose controls are accessible only to authorized personnel. This reliable external illumination source is to be energized at all times of building occupancy. Refer to listee's Installation Instruction Manual for details. Authority having jurisdiction should be consulted prior to installation.

05-31-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 23, 2006**

Listing Expires June 30, 2007

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**