

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 6200-1632:0101

Page 1 of 1

CATEGORY: 6200 -- EXIT SIGNS

LISTEE: ACTIVE SAFETY CORPORATION 5 East 4800 South, Murray, UT 84107
Contact: Scot Gordon (916) 989-3193 Fax (916) 989-1493
Email: sgordon@activesafety.com

DESIGN: Models ECO-CLEAR Series 2003 framed and frameless photoluminescent exit signs. Units illuminate a legally required integral "EXIT" legend, using Strontium Oxide Aluminate pigment to form the legend and directional indicators. The 2003 exit sign has a 3.175 mm to 6.35 mm acrylic substrate material with photoluminescent letters permanently attached spelling the word "EXIT" with optional directional indicators. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 90 minutes Legible viewing distance: 50 feet, Model 2003 Series

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. For indoor use only.

MARKING: Listee's name, model number, legible viewing distance, and ETL label.

APPROVAL: Listed as photoluminescent exit signs for use where permitted by code and only in locations where a minimum 5 foot-candle external unfiltered fluorescent illumination source is present on the sign face, is deemed reliable and is supplied by a circuit not controlled by automatic timers or sensors, and whose controls are accessible only to authorized personnel. This reliable external illumination source is to be energized at all times of building occupancy. Refer to listee's Installation Instruction Manual for details. Authority having jurisdiction should be consulted prior to installation.

07-13-2009 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2014**

Listing Expires **June 30, 2015**

Authorized By: **JAMES PARSESIAN, Program Coordinator**
Fire Engineering Division